CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012626 **REPORT No: 23-012626 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Amherstburg Public
P.O. NUMBER:
WATERWORKS NO: 500000677

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-Jun-05	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	AmPS-B2-S	AmPS-B2-F	AmPS-T9-S	AmPS-T9-F
			Sample I.D.	23-012626-1	23-012626-2	23-012626-3	23-012626-4
			Date Collected	2023-05-28	2023-05-28	2023-05-28	2023-05-28
Parameter	**Units**	**R.L.**		-	-	-	-
Lead	mg/L	0.00002		0.00335	0.00178	0.00023	0.00024

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012459 **REPORT No: 23-012459 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Anderdon Public
P.O. NUMBER:
WATERWORKS NO: 500022647

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-02	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	AND-B13-S	AND-B13-F
			Sample I.D.	23-012459-1	23-012459-2
			Date Collected	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00224	0.00156

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012413 **REPORT No: 23-012413 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-02
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Anderdon Public
P.O. NUMBER:
WATERWORKS NO: 500022647

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-01	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	AND-F14-S	AND-F14-F
			Sample I.D.	23-012413-1	23-012413-2
			Date Collected	2023-05-28	2023-05-28
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00268	0.00178

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010887 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-15
DATE REPORTED: 2023-May-31
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: A.V Graham Public
P.O. NUMBER:
WATERWORKS NO: 500023050

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	ASCHNEIDER	2023-May-26	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

		Parameter	Lead
		Units	mg/L
		R.L.	0.00002
Client I.D.	Sample I.D.	Date Collected	-
AVG-B8-S	23-010887-1	2023-May-13	0.00043
AVG-B8-F	23-010887-2	2023-May-13	0.00029

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010027 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-09
DATE REPORTED: 2023-May-17
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: A.V Graham Public
P.O. NUMBER:
WATERWORKS NO: 500023050

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-16	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	AVG-B9-S	AVG-B9-F
			Sample I.D.	23-010027-1	23-010027-2
			Date Collected	2023-05-06	2023-05-06
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00057	0.00020

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-014411 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-Jun-19	CUSTOMER PROJECT:	Belle River District HS
DATE REPORTED:	2023-Jun-28	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500022894

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-Jun-23	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	BRDHS B17-01-S	BRDHS B17-01-F	BRDHS F10-01-S	BRDHS F10-01-F
			Sample I.D.	23-014411-1	23-014411-2	23-014411-3	23-014411-4
			Date Collected	2023-06-10	2023-06-10	2023-06-10	2023-06-10
Parameter	**Units**	**R.L.**		-	-	-	-
Lead	mg/L	0.00002		0.00193	0.00092	0.00009	0.00006

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-014409 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-Jun-19	CUSTOMER PROJECT:	Belle River Public School
DATE REPORTED:	2023-Jun-28	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500022894

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-23	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	BRDHS B20 S 01	BRDHS B20 F 01
			Sample I.D.	23-014409-1	23-014409-2
			Date Collected	2023-06-11	2023-06-11
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00050	0.00028

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010006 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-09	CUSTOMER PROJECT:	Belle River Public School
DATE REPORTED:	2023-May-17	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500022881

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-May-16	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	BRPS-T7-S	BRPS-T7-F	BRPS-T9-S	BRPS-T9-F
			Sample I.D.	23-010006-1	23-010006-2	23-010006-3	23-010006-4
			Date Collected	2023-05-06	2023-05-06	2023-05-06	2023-05-06
Parameter	**Units**	**R.L.**		-	-	-	-
Lead	mg/L	0.00002		0.00373	0.00119	0.00203	0.00086

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010891 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-15	CUSTOMER PROJECT:	Bellewood
DATE REPORTED:	2023-May-31	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500023843

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-26	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

		Parameter	Lead
		Units	mg/L
		R.L.	0.00002
Client I.D.	Sample I.D.	Date Collected	-
BW-T14-S	23-010891-1	2023-May-13	0.00072
BW-T14-F	23-010891-2	2023-May-13	0.00035

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010003 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-09	CUSTOMER PROJECT:	Centennial Central
DATE REPORTED:	2023-May-17	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500022855

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-16	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	CCPS-F5-S	CCPS-F5-F
			Sample I.D.	23-010003-1	23-010003-2
			Date Collected	2023-05-06	2023-05-06
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00020	0.00012

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010889 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-15	CUSTOMER PROJECT:	Centennial Central
DATE REPORTED:	2023-May-31	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500022855

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-26	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

		Parameter	Lead
		Units	mg/L
		R.L.	0.00002
Client I.D.	Sample I.D.	Date Collected	-
CCPS-T9-S	23-010889-1	2023-May-13	0.00071
CCPS-T9-F	23-010889-2	2023-May-13	0.00028

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010904 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-15	CUSTOMER PROJECT:	Central Public School
DATE REPORTED:	2023-May-31	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500023427

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-26	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

		Parameter	Lead
		Units	mg/L
		R.L.	0.00002
Client I.D.	Sample I.D.	Date Collected	-
CEN-B11-S	23-010904-1	2023-May-14	0.00299
CEN-B11-F	23-010904-2	2023-May-14	0.00083

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-009971 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-09	CUSTOMER PROJECT:	Colcherster North
DATE REPORTED:	2023-May-17	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500061920

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-May-15	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

		Parameter	Lead
		Units	mg/L
		R.L.	0.00002
Client I.D.	Sample I.D.	Date Collected	-
CNPS-F8-S	23-009971-1	2023-May-07	0.00173
CNPS-F8-F	23-009971-2	2023-May-07	0.00086
CNPS-F2-S	23-009971-3	2023-May-07	0.00204
CNPS-F2-F	23-009971-4	2023-May-07	0.00098

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012465 **REPORT No: 23-012465 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-31	CUSTOMER PROJECT:	Coronation
DATE REPORTED:	2023-Jun-05	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500023180

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-02	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	CPS-F2-S	CPS-F2-F
			Sample I.D.	23-012465-1	23-012465-2
			Date Collected	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00069	0.00037

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012586 **REPORT No: 23-012586 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: David Maxwell Public School
P.O. NUMBER:
WATERWORKS NO: 500023258

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-02	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	MAX-B14-S	MAX-B14-F
			Sample I.D.	23-012586-1	23-012586-2
			Date Collected	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		<0.00002	<0.00002

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010026 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-09
DATE REPORTED: 2023-May-17
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: D.M Eagle
P.O. NUMBER:
WATERWORKS NO: 500023336

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-16	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	DME-F4-S	DME-F4-F
			Sample I.D.	23-010026-1	23-010026-2
			Date Collected	2023-05-06	2023-05-06
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00174	0.00144

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012464 **REPORT No: 23-012464 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Dougall
P.O. NUMBER:
WATERWORKS NO: 500023063

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-02	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	Doug-T10-S	Doug-T10-F
			Sample I.D.	23-012464-1	23-012464-2
			Date Collected	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00116	0.00045

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012589 **REPORT No: 23-012589 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Dr. David Suzuki
P.O. NUMBER:
WATERWORKS NO: 500023089

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-02	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	DSPS-T10-S	DSPS-T10-F
			Sample I.D.	23-012589-1	23-012589-2
			Date Collected	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00006	0.00002

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010913 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-15	CUSTOMER PROJECT:	East Mersea Public
DATE REPORTED:	2023-May-31	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500124450

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-May-26	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

		Parameter	Lead
		Units	mg/L
		R.L.	0.00002
Client I.D.	Sample I.D.	Date Collected	-
EMPS-B5-S	23-010913-1	2023-May-14	0.00077
EMPS-B5-F	23-010913-2	2023-May-14	0.00060
EMPS-F8-S	23-010913-3	2023-May-14	0.00027
EMPS-F8-F	23-010913-4	2023-May-14	0.00021

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-019293 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-Jul-31	CUSTOMER PROJECT:	Eastview Horizon P.S
DATE REPORTED:	2023-Aug-03	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500478011

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	40	OTTAWA	TPRICE	2023-Aug-01	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

		Parameter	Lead
		Units	mg/L
		R.L.	0.00002
		Limits	0.010
		DWG	MAC
Client I.D.	**Sample I.D.**	**Date Collected**	-
Tap 1 Rm 158-S	23-019293-1	2023-Jul-29	0.00032
Tap 1 Rm 158-F	23-019293-2	2023-Jul-29	0.00022
FTN #14 @ Rm153-S	23-019293-3	2023-Jul-29	0.00040
FTN #14 @ Rm153-F	23-019293-4	2023-Jul-29	0.00026
FTN #12 @ Rm126-S	23-019293-5	2023-Jul-29	0.00050
FTN #12 @ Rm126-F	23-019293-6	2023-Jul-29	0.00007
FTN 13 @ Gym-S	23-019293-7	2023-Jul-29	0.00014
FTN 13 @ Gym-F	23-019293-8	2023-Jul-29	0.00088
FTN 9 @ Rm122-S	23-019293-9	2023-Jul-29	0.00026
FTN 9 @ Rm122-F	23-019293-10	2023-Jul-29	0.00009

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

		Parameter	Lead
		Units	mg/L
		R.L.	0.00002
		Limits	0.010
		DWG	MAC
Client I.D.	**Sample I.D.**	**Date Collected**	-
Tap 8 @ Rm 116-S	23-019293-11	2023-Jul-29	0.00017
Tap 8 @ Rm 116-F	23-019293-12	2023-Jul-29	0.00055
tap 5 @ Kit 106-S	23-019293-13	2023-Jul-29	0.00035
tap 5 @ Kit 106-F	23-019293-14	2023-Jul-29	0.00161
Bottle CR 153-S	23-019293-15	2023-Jul-30	0.00034
Bottle CR 153-F	23-019293-16	2023-Jul-30	0.00016
Bottle Rm 126-S	23-019293-17	2023-Jul-30	0.00034
Bottle Rm 126-F	23-019293-18	2023-Jul-30	0.00018
Bottle 13@Gym-S	23-019293-19	2023-Jul-30	0.00066
Bottle 13@Gym-F	23-019293-20	2023-Jul-30	0.00019
Bottle 9 @ Rm 122-S	23-019293-21	2023-Jul-30	0.00024
Bottle 9 @ Rm 122-F	23-019293-22	2023-Jul-30	0.00021
Tap 6 Rm Kit 106-S	23-019293-23	2023-Jul-30	0.00105
Tap 6 Rm Kit 106-F	23-019293-24	2023-Jul-30	0.00023
Tap 7 @ Staff 102-S	23-019293-25	2023-Jul-30	0.00065
Tap 7 @ Staff 102-F	23-019293-26	2023-Jul-30	0.00026
FTN 3 @ WR 221-S	23-019293-27	2023-Jul-28	0.00032
FTN 3 @ WR 221-F	23-019293-28	2023-Jul-28	0.00044
FTN-4 @ WR 207-S	23-019293-29	2023-Jul-28	0.00010
FTN-4 @ WR 207-F	23-019293-30	2023-Jul-28	0.00025
Tap 11 in kit 128-S	23-019293-31	2023-Jul-28	0.00025



Lorina Merko

Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

		Parameter	Lead
		Units	mg/L
		R.L.	0.00002
		Limits	0.010
		DWG	MAC
Client I.D.	**Sample I.D.**	**Date Collected**	-
Tap 11 in kit 128-F	23-019293-32	2023-Jul-28	0.00019
FTN 3 @ WR 221 -S	23-019293-33	2023-Jul-28	0.00086
FTN 3 @ WR 221 -F	23-019293-34	2023-Jul-28	0.00022
Bottle 4 @ WR 207-S	23-019293-35	2023-Jul-28	0.00027
Bottle 4 @ WR 207-F	23-019293-36	2023-Jul-28	0.00069
Bottle 10 @ CR 125-S	23-019293-37	2023-Jul-29	0.00022
Bottle 10 @ CR 125-F	23-019293-38	2023-Jul-29	0.00033
FTN 10 @ CR 125-S	23-019293-39	2023-Jul-30	0.00026
FTN 10 @ CR 125-F	23-019293-40	2023-Jul-30	0.00065

DWG - Drinking Water Guidelines

ODWS - Ontario Drinking Water Standards
AO - Aesthetic Objectives
IMAC - Interim Maximum Acceptable Concentration
MAC - Maximum Acceptable Concentration
ODWO - D-5-5 Objective
OG - Operational Guidelines
WL - Warning Level - Sodium Restricted Diets



Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012410 **REPORT No: 23-012410 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-31	CUSTOMER PROJECT:	Eastwood
DATE REPORTED:	2023-Jun-02	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500023193

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-01	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	EAS-F11-S	EAS-F11-F
			Sample I.D.	23-012410-1	23-012410-2
			Date Collected	2023-05-22	2023-05-22
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00088	0.00078

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-009996 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-09
DATE REPORTED: 2023-May-17
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Essex District High School
P.O. NUMBER:
WATERWORKS NO: 500022777

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-May-16	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	EDHS- B15-S	EDHS- B15-F	EDHS- B5-S	EDHS- B5-F
			Sample I.D.	23-009996-1	23-009996-2	23-009996-3	23-009996-4
			Date Collected	2023-05-06	2023-05-06	2023-05-06	2023-05-06
Parameter	**Units**	**R.L.**		-	-	-	-
Lead	mg/L	0.00002		<0.00002	<0.00002	0.00003	0.00003

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010001 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-09	CUSTOMER PROJECT:	Essex Public School
DATE REPORTED:	2023-May-17	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500022699

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-May-16	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	EPS-F8-S	EPS-F8-F	EPS-T20-S	EPS-T20-F
			Sample I.D.	23-010001-1	23-010001-2	23-010001-3	23-010001-4
			Date Collected	2023-05-06	2023-05-06	2023-05-06	2023-05-06
Parameter	**Units**	**R.L.**		-	-	-	-
Lead	mg/L	0.00002		0.00446	0.00225	0.00030	0.00014

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012460 **REPORT No: 23-012460 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Ford City Elementary
P.O. NUMBER:
WATERWORKS NO: 500004252

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-02	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	Ford-B3-S	Ford-B3-F
			Sample I.D.	23-012460-1	23-012460-2
			Date Collected	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00050	0.00026

Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012597 **REPORT No: 23-012597 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Forest Glade Primary Learning C
P.O. NUMBER:
WATERWORKS NO: 500023219

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-02	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	FGPLC-F11-S	FGPLC-F11-F
			Sample I.D.	23-012597-1	23-012597-2
			Date Collected	2023-05-28	2023-05-28
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00334	0.00185

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-014403 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED: 2023-Jun-19
DATE REPORTED: 2023-Jun-28
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Forest Glade
P.O. NUMBER:
WATERWORKS NO: 500023206

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-23	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	FGPS-F6-S	FGPS-F6-S
			Sample I.D.	23-014403-1	23-014403-2
			Date Collected	2023-06-03	2023-06-03
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00144	0.00064

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012577 **REPORT No: 23-012577 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Frank Begley Public School
P.O. NUMBER:
WATERWORKS NO: 500023440

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-02	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	BEG-B3-S	BEG-B3-F
			Sample I.D.	23-012577-1	23-012577-2
			Date Collected	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		<0.00002	<0.00002

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012435 **REPORT No: 23-012435 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-02
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: General Brock
P.O. NUMBER:
WATERWORKS NO: 500026521

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-01	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	BROCK-B10-S	BROCK-B10-F
			Sample I.D.	23-012435-1	23-012435-2
			Date Collected	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00026	0.00009

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010895 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-15	CUSTOMER PROJECT:	Glenwood
DATE REPORTED:	2023-May-31	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500023713

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-May-26	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

		Parameter	Lead
		Units	mg/L
		R.L.	0.00002
Client I.D.	Sample I.D.	Date Collected	-
GW-B3-S	23-010895-1	2023-May-13	0.00051
GW-B3-F	23-010895-2	2023-May-13	0.00034
GW-T1-S	23-010895-3	2023-May-13	0.00540
GW-T1-F	23-010895-4	2023-May-13	0.00068

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010929 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-15
DATE REPORTED: 2023-May-31
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Gore Hill Public School
P.O. NUMBER:
WATERWORKS NO: 500022972

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-26	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

		Parameter	Lead
		Units	mg/L
		R.L.	0.00002
Client I.D.	Sample I.D.	Date Collected	-
GHPS-B9-S	23-010929-1	2023-May-14	0.00196
GHPS-B9-F	23-010929-2	2023-May-14	0.00076

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010023 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-09
DATE REPORTED: 2023-May-17
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Gore Hill Public School
P.O. NUMBER:
WATERWORKS NO: 500022972

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-May-16	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	GHPS-B10-S	GHPS-B10-F	GHPS-T6A-S	GHPS-T6A-F
			Sample I.D.	23-010023-1	23-010023-2	23-010023-3	23-010023-4
			Date Collected	2023-05-07	2023-05-07	2023-05-07	2023-05-07
Parameter	**Units**	**R.L.**		-	-	-	-
Lead	mg/L	0.00002		0.00193	0.00099	0.00339	0.00149

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010000 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-09	CUSTOMER PROJECT:	Gosfield North
DATE REPORTED:	2023-May-17	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500124463

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-16	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	GNDS-F18-S	GNDS-F18-F
			Sample I.D.	23-010000-1	23-010000-2
			Date Collected	2023-05-06	2023-05-06
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00179	0.00234

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012603 **REPORT No: 23-012603 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Harrow Public School
P.O. NUMBER:
WATERWORKS NO: 500022764

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-Jun-02	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	HPS-T12-S	HPS-T12-F	HPS-B6-S	HPS-B6-F
			Sample I.D.	23-012603-1	23-012603-2	23-012603-3	23-012603-4
			Date Collected	2023-05-27	2023-05-27	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-	-	-
Lead	mg/L	0.00002		0.00054	0.00046	0.00007	0.00006

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012466 **REPORT No: 23-012466 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Hon W. C. Kennedy
P.O. NUMBER:
WATERWORKS NO: 500023375

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-02	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	KEN-T15-S	KEN-T15-F
			Sample I.D.	23-012466-1	23-012466-2
			Date Collected	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00053	0.00100

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012617 **REPORT No: 23-012617 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Kennedy North
P.O. NUMBER:
WATERWORKS NO: 500312352

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-Jun-05	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

				Client I.D.	Nken-T1-S	Nken-T1-F	Nken-F2-S	Nken-F2-F
				Sample I.D.	23-012617-1	23-012617-2	23-012617-3	23-012617-4
				Date Collected	2023-May-13	2023-May-13	2023-May-27	2023-May-27
Parameter	**Units**	**R.L.**	**Limits**	**DWG**	-	-	-	-
Lead	mg/L	0.00002	0.010	MAC	0.00050	0.00016	**0.0134**	0.00405

DWG - Drinking Water Guidelines
ODWS - Ontario Drinking Water Standards
AO - Aesthetic Objectives
IMAC - Interim Maximum Acceptable Concentration
MAC - Maximum Acceptable Concentration
ODWO - D-5-5 Objective
OG - Operational Guidelines
WL - Warning Level - Sodium Restricted Diets

Summary of Exceedances

Maximum Acceptable Concentration

Nken-F2-S	Found Value	Limit
Lead	0.0134	0.010

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-014369 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-Jun-19	CUSTOMER PROJECT:	Kennedy North
DATE REPORTED:	2023-Jun-28	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500023375

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-23	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

				Client I.D.	KN-F2-S	KN-F2-F
				Sample I.D.	23-014369-1	23-014369-2
				Date Collected	2023-Jun-17	2023-Jun-17
Parameter	Units	R.L.	Limits	DWG	-	-
Lead	mg/L	0.00002	0.010	MAC	**0.0119**	0.00234

Results Indicate Adverse Water Quality

DWG - Drinking Water Guidelines
ODWS - Ontario Drinking Water Standards
AO - Aesthetic Objectives
IMAC - Interim Maximum Acceptable Concentration
MAC - Maximum Acceptable Concentration
ODWO - D-5-5 Objective
OG - Operational Guidelines
WL - Warning Level - Sodium Restricted Diets

Summary of Exceedances

Maximum Acceptable Concentration

KN-F2-S	Found Value	Limit
Lead	0.0119	0.010

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012400 **REPORT No: 23-012400 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-02
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Hugh Beaton
P.O. NUMBER:
WATERWORKS NO: 500023284

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-Jun-01	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	HB-T1-S	HB-T1-F	HB-T11-S	HB-T11-F
			Sample I.D.	23-012400-1	23-012400-2	23-012400-3	23-012400-4
			Date Collected	2023-05-13	2023-05-13	2023-05-13	2023-05-13
Parameter	**Units**	**R.L.**		-	-	-	-
Lead	mg/L	0.00002		0.00295	0.00016	0.00057	0.00071

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010892 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-15
DATE REPORTED: 2023-May-31
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: John A.McWilliam
P.O. NUMBER:
WATERWORKS NO: 500023414

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-26	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

		Parameter	Lead
		Units	mg/L
		R.L.	0.00002
Client I.D.	Sample I.D.	Date Collected	-
MCW-T5-S	23-010892-1	2023-May-13	0.00088
MCW-T5-F	23-010892-2	2023-May-13	0.00079

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010034 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-09
DATE REPORTED: 2023-May-17
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Jack Miner
P.O. NUMBER:
WATERWORKS NO: 500022790

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-16	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	JM-B9-S	JM-B9-F
			Sample I.D.	23-010034-1	23-010034-2
			Date Collected	2023-05-06	2023-05-06
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00177	0.00205

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012624 **REPORT No: 23-012624 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: James L Dunn
P.O. NUMBER:
WATERWORKS NO: 500468326

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-05	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	DUNN-T21-S	SUNN-T21-F
			Sample I.D.	23-012624-1	23-012624-2
			Date Collected	2023-05-28	2023-05-28
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00015	0.00008

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012581 **REPORT No: 23-012581 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: John Campbell
P.O. NUMBER:
WATERWORKS NO: 500023349

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-02	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	JC-F5-S	JC-F5-F
			Sample I.D.	23-012581-1	23-012581-2
			Date Collected	2023-05-13	2023-05-13
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00003	0.00004

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012573 **REPORT No: 23-012573 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: King Edward
P.O. NUMBER:
WATERWORKS NO: 500023297

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-02	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	KE-F13-S	KE-F13-F
			Sample I.D.	23-012573-1	23-012573-2
			Date Collected	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00007	0.00004

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010029 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-09
DATE REPORTED: 2023-May-17
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Kingsville District High School
P.O. NUMBER:
WATERWORKS NO: 500022816

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-16	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

				Client I.D.	KDHS-F6-S	KDHS-F6-F
				Sample I.D.	23-010029-1	23-010029-2
				Date Collected	2023-May-06	2023-May-06
Parameter	**Units**	**R.L.**	**Limits**	**DWG**	-	-
Lead	mg/L	0.00002	0.010	MAC	**0.0103**	0.00449

Adverse: Reported 23-05-17

DWG - Drinking Water Guidelines
ODWS - Ontario Drinking Water Standards
AO - Aesthetic Objectives
IMAC - Interim Maximum Acceptable Concentration
MAC - Maximum Acceptable Concentration
ODWO - D-5-5 Objective
OG - Operational Guidelines
WL - Warning Level - Sodium Restricted Diets

Summary of Exceedances

Maximum Acceptable Concentration

KDHS-F6-S	Found Value	Limit
Lead	0.0103	0.010

Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012601 **REPORT No: 23-012601 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Kingsville District High School
P.O. NUMBER:
WATERWORKS NO: 500022816

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-02	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	KDHS-F6-S	KDHS-F6-F
			Sample I.D.	23-012601-1	23-012601-2
			Date Collected	2023-05-28	2023-05-28
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00654	0.00352

Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010032 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-09	CUSTOMER PROJECT:	Kingsville Public School
DATE REPORTED:	2023-May-17	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500022803

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-16	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	KP-B6-S	KP-B6-F
			Sample I.D.	23-010032-1	23-010032-2
			Date Collected	2023-05-06	2023-05-10
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00184	0.00062

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010885 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-15	CUSTOMER PROJECT:	Lakeshore Discovery
DATE REPORTED:	2023-May-31	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500022868

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	6	OTTAWA	ASCHNEIDER	2023-May-26	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

		Parameter	Lead
		Units	mg/L
		R.L.	0.00002
Client I.D.	Sample I.D.	Date Collected	-
LAK-B15-S	23-010885-1	2023-May-13	0.00006
LAK-B15-F	23-010885-2	2023-May-13	0.00006
LAK-B21-S	23-010885-3	2023-May-13	0.00010
LAK-B21-F	23-010885-4	2023-May-13	0.00009
LAK-T2-S	23-010885-5	2023-May-13	0.00017
LAK-T2-F	23-010885-6	2023-May-13	0.00017

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012613 **REPORT No: 23-012613 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: LaSalle Public
P.O. NUMBER:
WATERWORKS NO: 500022920

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-Jun-05	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	LPS-B8-S	LPS-B8-F	LPS-B4-S	LPS-B4-F
			Sample I.D.	23-012613-1	23-012613-2	23-012613-3	23-012613-4
			Date Collected	2023-05-27	2023-05-27	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-	-	-
Lead	mg/L	0.00002		0.00218	0.00134	0.00084	0.00038

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010007 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-09	CUSTOMER PROJECT:	Leamington District Secondary Sc
DATE REPORTED:	2023-May-17	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500436216

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-16	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	LDHS-T30-S	LDHS-T30-F
			Sample I.D.	23-010007-1	23-010007-2
			Date Collected	2023-05-07	2023-05-07
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00126	0.00028

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012415 **REPORT No: 23-012415 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-02
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Legacy Oak Trail
P.O. NUMBER:
WATERWORKS NO: 500460799

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-01	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	LOT-BS-S	LOT-BS-F
			Sample I.D.	23-012415-1	23-012415-2
			Date Collected	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00003	0.00003

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012421 **REPORT No: 23-012421 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-02
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Legacy Oak Trail
P.O. NUMBER:
WATERWORKS NO: 500460799

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-01	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	LOT-T6-S	LOT-T6-F
			Sample I.D.	23-012421-1	23-012421-2
			Date Collected	2023-05-28	2023-05-28
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00056	0.00011

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010020 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-09
DATE REPORTED: 2023-May-17
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Margaert D. Bennie
P.O. NUMBER:
WATERWORKS NO: 500022985

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-16	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	MDB-B8-S	MDB-B8-F
			Sample I.D.	23-010020-1	23-010020-2
			Date Collected	2023-05-07	2023-05-07
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00069	0.00044

Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010897 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-15
DATE REPORTED: 2023-May-31
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: M.S Hetherington
P.O. NUMBER:
WATERWORKS NO: 500023726

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-26	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

		Parameter	Lead
		Units	mg/L
		R.L.	0.00002
Client I.D.	Sample I.D.	Date Collected	-
MSH-B13-S	23-010897-1	2023-May-13	0.00064
MSH-B13-F	23-010897-2	2023-May-13	0.00030

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010004 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-09
DATE REPORTED: 2023-May-17
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: M.S Hetherington
P.O. NUMBER:
WATERWORKS NO: 500023726

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-16	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	Heth-T1-S	Heth-T1-F
			Sample I.D.	23-010004-1	23-010004-2
			Date Collected	2023-05-06	2023-05-06
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00049	0.00017

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010900 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-15
DATE REPORTED: 2023-May-31
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: M.S Hetherington
P.O. NUMBER:
WATERWORKS NO: 500023726

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-26	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

Client I.D.	Sample I.D.	Date Collected	Parameter: Lead
		Units	mg/L
		R.L.	0.00002
			-
MSH-F13-S	23-010900-1	2023-May-14	0.00064
MSH-F13-F	23-010900-2	2023-May-14	0.00032

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012419 **REPORT No: 23-012419 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-02
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Malden Central
P.O. NUMBER:
WATERWORKS NO: 500124437

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-01	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	MCPS-T4-S	MCPS-T4-F
			Sample I.D.	23-012419-1	23-012419-2
			Date Collected	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00180	0.00085

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012450 **REPORT No: 23-012450 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-31	CUSTOMER PROJECT:	Marlborough
DATE REPORTED:	2023-Jun-05	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500023310

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-02	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	MARL-F6-S	MARL-F6-S
			Sample I.D.	23-012450-1	23-012450-2
			Date Collected	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00006	0.00007

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012461 **REPORT No: 23-012461 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Mason Educational Centre
P.O. NUMBER:
WATERWORKS NO: 500023141

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-05	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	MEC-T1-S	MEC-T1-F
			Sample I.D.	23-012461-1	23-012461-2
			Date Collected	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00322	0.00179

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-009989 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-09	CUSTOMER PROJECT:	Mount Carmel- Blytheswood
DATE REPORTED:	2023-May-17	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500124476

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-16	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	MCB-B10-S	MCB-B10-F
			Sample I.D.	23-009989-1	23-009989-2
			Date Collected	2023-05-07	2023-05-07
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00039	0.00029

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012420 **REPORT No: 23-012420 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-02
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: North Star District High School
P.O. NUMBER:
WATERWORKS NO: 500468339

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-01	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	NSDHS-TS-S	NSDHS-TS-F
			Sample I.D.	23-012420-1	23-012420-2
			Date Collected	2023-05-28	2023-05-28
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00318	0.00029

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012616 **REPORT No: 23-012616 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: North Star District High School
P.O. NUMBER:
WATERWORKS NO: 500468339

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-Jun-05	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	NSDHS-T8-S	NSDHS-T8-F	NSDHS-T7-S	NSDHS-T7-F
			Sample I.D.	23-012616-1	23-012616-2	23-012616-3	23-012616-4
			Date Collected	2023-05-27	2023-05-27	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-	-	-
Lead	mg/L	0.00002		0.00687	0.00084	0.00310	0.00034

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010909 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-15	CUSTOMER PROJECT:	Northwood
DATE REPORTED:	2023-May-31	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500023232

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-May-26	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

		Parameter	Lead
		Units	mg/L
		R.L.	0.00002
Client I.D.	Sample I.D.	Date Collected	-
NW-T18-S	23-010909-1	2023-May-14	0.00220
NW-T18-F	23-010909-2	2023-May-14	0.00011
NW-B11-S	23-010909-3	2023-May-14	0.00019
NW-B11-F	23-010909-4	2023-May-14	0.00066

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-014368 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED: 2023-Jun-19
DATE REPORTED: 2023-Jun-28
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Pelee Island Public School
P.O. NUMBER:
WATERWORKS NO: 500022842

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-23	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	PIPS-F4-S	PIPS-F4-F
			Sample I.D.	23-014368-1	23-014368-2
			Date Collected	2023-06-02	2023-06-02
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00057	0.00061

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012618 **REPORT No: 23-012618 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Prince Edward
P.O. NUMBER:
WATERWORKS NO: 500023167

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-Jun-05	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	PE-T11-S	PE-T11-F	PE-F20-S	PE-F20-F
			Sample I.D.	23-012618-1	23-012618-2	23-012618-3	23-012618-4
			Date Collected	2023-05-28	2023-05-28	2023-05-28	2023-05-28
Parameter	**Units**	**R.L.**		-	-	-	-
Lead	mg/L	0.00002		0.00003	0.00003	0.00004	0.00004

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012572 **REPORT No: 23-012572 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Princess Elizabeth
P.O. NUMBER:
WATERWORKS NO: 500023869

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-02	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	PELiz-T2-S	PEliz-T2-F
			Sample I.D.	23-012572-1	23-012572-2
			Date Collected	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00025	0.00014

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010022 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-09
DATE REPORTED: 2023-May-17
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Queen Elizabeth
P.O. NUMBER:
WATERWORKS NO: 500022959

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-16	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	QEPS-B5-S	QEPS-B5-F
			Sample I.D.	23-010022-1	23-010022-2
			Date Collected	2023-05-07	2023-05-07
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00474	0.00262

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010927 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-15	CUSTOMER PROJECT:	Queen Elizabeth
DATE REPORTED:	2023-May-31	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500022959

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-26	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

		Parameter	Lead
		Units	mg/L
		R.L.	0.00002
Client I.D.	Sample I.D.	Date Collected	-
QEPS-F5-S	23-010927-1	2023-May-14	0.00488
QEPS-F5-F	23-010927-2	2023-May-14	0.00148

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012614 **REPORT No: 23-012614 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Riverside Secondary School
P.O. NUMBER:
WATERWORKS NO: 500023778

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-05	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	RS-F6-S	RS-F6-F
			Sample I.D.	23-012614-1	23-012614-2
			Date Collected	2023-05-28	2023-05-28
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00005	0.00003

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-009994 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-09	CUSTOMER PROJECT:	Roseland
DATE REPORTED:	2023-May-17	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500023362

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-May-16	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	RPS-F12-S	RPS-F12-F	RPS-F2-S	RPS-F2-F
			Sample I.D.	23-009994-1	23-009994-2	23-009994-3	23-009994-4
			Date Collected	2023-05-06	2023-05-06	2023-05-06	2023-05-06
Parameter	**Units**	**R.L.**		-	-	-	-
Lead	mg/L	0.00002		0.00004	0.00003	0.00021	0.00026

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012463 **REPORT No: 23-012463 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Roseville
P.O. NUMBER:
WATERWORKS NO: 500023245

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-02	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	RVPS-B8-S	RVPS-B8-F
			Sample I.D.	23-012463-1	23-012463-2
			Date Collected	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00033	0.00108

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012606 **REPORT No: 23-012606 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Sandwich Secondary
P.O. NUMBER:
WATERWORKS NO: 500022946

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-Jun-02	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	SSS-T10-S	SSS-T10-F	SSS-T24-S	SSS-T24-F
			Sample I.D.	23-012606-1	23-012606-2	23-012606-3	23-012606-4
			Date Collected	2023-05-27	2023-05-27	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-	-	-
Lead	mg/L	0.00002		0.00145	0.00046	0.00216	0.00037

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012422 **REPORT No: 23-012422 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-31	CUSTOMER PROJECT:	Sandwich Secondary
DATE REPORTED:	2023-Jun-02	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500022946

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-01	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	SSS-T25-S	SSS-T25-F
			Sample I.D.	23-012422-1	23-012422-2
			Date Collected	2023-05-28	2023-05-28
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00089	0.00040

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012609 **REPORT No: 23-012609 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Sandwich West
P.O. NUMBER:
WATERWORKS NO: 500022933

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-Jun-05	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

				Client I.D.	SWPS-F13-S	SWPS-F13-F	SWPS-T21-S	SWPS-T21-F
				Sample I.D.	23-012609-1	23-012609-2	23-012609-3	23-012609-4
				Date Collected	2023-May-27	2023-May-27	2023-May-27	2023-May-27
Parameter	**Units**	**R.L.**	**Limits**	**DWG**	-	-	-	-
Lead	mg/L	0.00002	0.010	MAC	0.00054	0.00019	**0.0101**	0.00150

Lead adverse (sample #3) = 10.06 ug/L
Reported 23/06/05

DWG - Drinking Water Guidelines
ODWS - Ontario Drinking Water Standards
AO - Aesthetic Objectives
IMAC - Interim Maximum Acceptable Concentration
MAC - Maximum Acceptable Concentration
ODWO - D-5-5 Objective
OG - Operational Guidelines
WL - Warning Level - Sodium Restricted Diets

Summary of Exceedances

Maximum Acceptable Concentration

SWPS-T21-S	Found Value	Limit
Lead	0.0101	0.010

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010910 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-15	CUSTOMER PROJECT:	Southwood
DATE REPORTED:	2023-May-31	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500023401

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-26	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

		Parameter	Lead
		Units	mg/L
		R.L.	0.00002
Client I.D.	Sample I.D.	Date Collected	-
SW-T1-S	23-010910-1	2023-May-14	0.00015
SW-T1-F	23-010910-2	2023-May-14	0.00003

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-014395 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-Jun-19	CUSTOMER PROJECT:	Sandwich West
DATE REPORTED:	2023-Jun-28	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500022946

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-23	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	SW-T21-S	SW-T21-F
			Sample I.D.	23-014395-1	23-014395-2
			Date Collected	2023-06-17	2023-06-17
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00333	0.00116

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010910 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-15	CUSTOMER PROJECT:	Southwood
DATE REPORTED:	2023-May-31	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500023401

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-26	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

		Parameter	Lead
		Units	mg/L
		R.L.	0.00002
Client I.D.	Sample I.D.	Date Collected	-
SW-T1-S	23-010910-1	2023-May-14	0.00015
SW-T1-F	23-010910-2	2023-May-14	0.00003

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010911 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-15	CUSTOMER PROJECT:	Talbot Trail Public School
DATE REPORTED:	2023-May-31	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500023752

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-May-26	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

		Parameter	Lead
		Units	mg/L
		R.L.	0.00002
Client I.D.	Sample I.D.	Date Collected	-
TTPS-T8C-S	23-010911-1	2023-May-14	0.00009
TTPS-T8C-F	23-010911-2	2023-May-14	0.00005

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010881 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-15
DATE REPORTED: 2023-May-26
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Tecumseh Vista Academy K-12
P.O. NUMBER:
WATERWORKS NO: 500269114

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	8	OTTAWA	TPRICE	2023-May-19	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

Client I.D.	Sample I.D.	Date Collected	Parameter: Lead
		Units	mg/L
		R.L.	0.00002
			-
TVA-B10-S	23-010881-1	2023-May-14	0.00007
TVA-B10-F	23-010881-2	2023-May-14	0.00012
TVA-F33A-S	23-010881-3	2023-May-14	0.00008
TVA-F33A-F	23-010881-4	2023-May-14	0.00004
TVA-B22-S	23-010881-5	2023-May-14	0.00028
TVA-B22-F	23-010881-6	2023-May-14	0.00005
TVA-B31-S	23-010881-7	2023-May-14	0.00003
TVA-B31-F	23-010881-8	2023-May-14	0.00003

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 23-010906 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
5-3201 Marentette Ave
Windsor, ON N8X 4G3

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-15	CUSTOMER PROJECT:	Vincent Massey
DATE REPORTED:	2023-May-31	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500023791

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-May-26	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

		Parameter	Lead
		Units	mg/L
		R.L.	0.00002
Client I.D.	Sample I.D.	Date Collected	-
VM-B19-S	23-010906-1	2023-May-14	0.00003
VM-B19-F	23-010906-2	2023-May-14	0.00003
VM-B14-S	23-010906-3	2023-May-14	0.00002
VM-B14-F	23-010906-4	2023-May-14	<0.00002

Lorina Merko
Laboratory Manager

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012406 **REPORT No: 23-012406 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-02
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: W. F. Herman Academy
P.O. NUMBER:
WATERWORKS NO: 500023154

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	4	OTTAWA	TPRICE	2023-Jun-01	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	HER-B39-S	HER-B39-F	HER-F14-S	HER-F14-F
			Sample I.D.	23-012406-1	23-012406-2	23-012406-3	23-012406-4
			Date Collected	2023-05-27	2023-05-27	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-	-	-
Lead	mg/L	0.00002		0.00031	0.00018	0.00085	0.00043

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012575 **REPORT No: 23-012575 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED:	2023-May-31	CUSTOMER PROJECT:	Walkerville
DATE REPORTED:	2023-Jun-05	P.O. NUMBER:	
SAMPLE MATRIX:	Drinking Water	WATERWORKS NO:	500023817

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-02	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	Walk-Bb-S	Walk-Bb-F
			Sample I.D.	23-012575-1	23-012575-2
			Date Collected	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00002	0.00002

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012427 **REPORT No: 23-012427 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-02
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: West Gate Public School
P.O. NUMBER:
WATERWORKS NO: 500367485

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-01	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	WG-B12-S	WG-B12-F
			Sample I.D.	23-012427-1	23-012427-2
			Date Collected	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00002	<0.00002

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012622 **REPORT No: 23-012622 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Westview Freedom Academy
P.O. NUMBER:
WATERWORKS NO: 500023115

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	6	OTTAWA	TPRICE	2023-Jun-05	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	WFA-B31-S	WFA-B31-F	WFA-T21-S	WFA-T21-F	WFA-T6-S
			Sample I.D.	23-012622-1	23-012622-2	23-012622-3	23-012622-4	23-012622-5
			Date Collected	2023-05-28	2023-05-28	2023-05-28	2023-05-28	2023-05-28
Parameter	**Units**	**R.L.**		-	-	-	-	-
Lead	mg/L	0.00002		0.00167	0.00106	0.00053	0.00041	0.00010

			Client I.D.	WFA-T6-F
			Sample I.D.	23-012622-6
			Date Collected	2023-05-28
Parameter	**Units**	**R.L.**		-
Lead	mg/L	0.00002		0.00004

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012456 **REPORT No: 23-012456 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-05
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Westview Freedom Academy
P.O. NUMBER:
WATERWORKS NO: 500023115

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-02	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	WFA-F31-S	WFA-F31-F
			Sample I.D.	23-012456-1	23-012456-2
			Date Collected	2023-05-27	2023-05-27
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00153	0.00065

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Canadian owned.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: DW 012412 **REPORT No: 23-012412 - Rev. 0**

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Rachel Bondy

DATE RECEIVED: 2023-May-31
DATE REPORTED: 2023-Jun-02
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: William G Davis
P.O. NUMBER:
WATERWORKS NO: 500023765

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	TPRICE	2023-Jun-01	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	DAV-B4-S	DAV-B4-F
			Sample I.D.	23-012412-1	23-012412-2
			Date Collected	2023-05-22	2023-05-22
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00075	0.00049

Shelly Lozo
Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.