CADUCEON ENVIRONMENTAL LABORATORIES
Client committed. Quality assured. Proudly Canadian.

CERTIFICATE OF ANALYSIS

Final Report

C.O.C.: -

REPORT No: 25-028290 - Rev. 0

Report To:
Greater Essex County District School Board
280 Eugenie St. E
Windsor, ON N8X 2X8

CADUCEON Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Attention: Carly Jacobs

DATE RECEIVED: 2025-Sep-16
DATE REPORTED: 2025-Sep-17
SAMPLE MATRIX: Drinking Water

CUSTOMER PROJECT: Talbot Trail Public School
P.O. NUMBER:
WATERWORKS NO: 500023752

Analyses	Qty	Site Analyzed	Authorized	Date Analyzed	Lab Method	Reference Method
ICP/MS (Liquid)	2	OTTAWA	GFENTON	2025-Sep-17	D-ICPMS-01	EPA 200.8

R.L. = Reporting Limit
NC = Not Calculated
Test methods may be modified from specified reference method unless indicated by an *

			Client I.D.	TT-B9-S	TT-B9-F
			Sample I.D.	25-028290-1	25-028290-2
			Date Collected	2025-09-14	2025-09-14
Parameter	**Units**	**R.L.**		-	-
Lead	mg/L	0.00002		0.00003	0.00006

Shelly Lozo
Microbiology Supervisor

The analytical results reported herein refer to the samples as received and relate only to the items tested. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.